



Product certificate K40835/05

Issued 2022-02-01

Replaces K40835/04

Page 1 of 2

Stainless steel tubes - InoxPRES®

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Raccorderie Metalliche S.p.A.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K762 "Seamless and welded stainless steel tubes for drinking water applications" dated 2018-01-16.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

28171015

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company

Raccorderie Metalliche S.p.A.
Strada Sabbionetana 59
46010 CAMPITELLO DI M. (MN)
Italy
Tel. +39 376 96001
www.racmet.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Stainless steel tubes - InoxPRES®

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

TIG welded stainless steel tubes of EN 1.4404 (AISI 316L) according to delivery conditions in EN 10217-7 (DIN 17457) or according to EN 10312 series 2 in the dimensions 15 mm x 1,0 mm to 108 mm x 2,0 mm.

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation", dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;

- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA" together with  or the abbreviated word mark .

Place of the mark: on the outside of the tube, at maximum intervals of 500 mm.

Compulsory specifications:

- manufacturer's name or mark;
- production date or code;
- type specification;
- outer diameter;
- material type.

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are suitable for use with stainless steel press fittings according to BRL-K774 "Compression fittings to tighten with matching clamping device" in drinking water installations with a maximum nominal pressure of 1,6 MPa and a maximum temperature of 90°C.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Raccorderie Metalliche S.p.A.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.