



## Certificate of Compliance

This certificate is issued for the following:

### Press-Fit Pipe Fittings for Use in Aboveground Fire Protection Systems

Stainless Steel Press-Fit Pipe Fittings for Use with Aboveground Fire Protection Systems

15, 18, 22, 28, 35, 42, 54, 76.1, 88.9, 108 mm

Model 116/200, 114/200 and 116/300 Stainless Steel Specialty Tubes Manufactured to EN 10312 Specifications

#### Prepared for:

Raccorderie Metalliche SpA  
Strada Sabbionetana, 59  
Campitello di Marcaria 46010  
Italy

#### Manufactured at:

Raccorderie Metalliche SpA  
Strada Sabbionetana, 59  
Campitello di Marcaria 46010  
Italy

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”  
(November, 2007)

Approval Identification: PR465065

Approval Granted: 26 March 2025

Date of Reissue: 12 June 2025

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller  
VP - Manager of Fire Protection  
FM Approvals  
One Technology Way  
Norwood, MA 02062





## Certificate of Compliance

This certificate is issued for the following:

### Specialty Tube for Aboveground Fire Protection Systems

Stainless Steel Specialty Tubulars for Use with Aboveground Fire Protection Systems

Model 116/200, Model 114/200 and Model 116/030

15, 18, 22, 28, 35, 42, 54, 76.1, 88.9, 108 mm

#### Prepared for:

Raccorderie Metalliche SpA  
Strada Sabbionetana, 59  
Campitello di Marcaria 46010  
Italy

#### Manufactured at:

Raccorderie Metalliche SpA  
Strada Sabbionetana, 59  
Campitello di Marcaria 46010  
Italy

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems” (June, 2021)

Approval Identification: PR465065

Approval Granted: 26 March 2025  
Report Reissued: 11 June 2025

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller  
VP - Manager of Fire Protection  
FM Approvals  
One Technology Way  
Norwood, MA 02062





## Certificate of Compliance

This certificate is issued for the following:

### Press-Fit Pipe Fittings for Use in Aboveground Fire Protection Systems

Stainless Steel Press-Fit Pipe Fittings for Use with Aboveground Fire Protection Systems

15, 18, 22, 28, 35, 42, 54, 76.1, 88.9, 108 mm

Model 116/200, 114/200 and 116/300 Stainless Steel Specialty Tubes Manufactured to EN 10312 Specifications

#### Prepared for:

Raccorderie Metalliche SpA  
Strada Sabbionetana, 59  
Campitello di Marcaria 46010  
Italy

#### Manufactured at:

Raccorderie Metalliche SpA  
Via Montanara Sud, 128  
Pilastro de Marcaria (MN) 46010  
Italy

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”  
(November, 2007)

Approval Identification: PR465065

Approval Granted: 26 March 2025  
Report Reissued: 11 June 2025

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller  
VP - Manager of Fire Protection  
FM Approvals  
One Technology Way  
Norwood, MA 02062





## Certificate of Compliance

This certificate is issued for the following:

### Specialty Tube for Aboveground Fire Protection Systems

Stainless Steel Specialty Tubulars for Use with Aboveground Fire Protection Systems

Model 116/200, Model 114/200 and Model 116/030

15, 18, 22, 28, 35, 42, 54, 76.1, 88.9, 108 mm

#### Prepared for:

Raccorderie Metalliche SpA  
Strada Sabbionetana, 59  
Campitello di Marcaria 46010  
Italy

#### Manufactured at:

Raccorderie Metalliche SpA  
Via Montanara Sud, 128  
Pilastro de Marcaria (MN) 46010  
Italy

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems” (June, 2021)

Approval Identification: PR465065

Approval Granted: 26 March 2025

Report Reissued: 11 June 2025

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller  
VP - Manager of Fire Protection  
FM Approvals  
One Technology Way  
Norwood, MA 02062

